

TENDER FORM

Sealed Tenders are invited from Manufacturers/Authorised Dealers for the job.

S.No.	Description of material.	Quantity	Rate.
1.	Filtrations and Dehydration of Transformer Oil and testing of the same for dielectric strength of 30 KV at 2.5 mm gap for On line filtration of 1000 KVA and 2000 KVA. Transformer (Break down voltage test transformer oil)	2 Nos.	
2.	Supply of Silica Gel for Transformer.	1.0 kg.	

Note:- quantity may be increase or decrease at the time of order.

TERMS AND CONDITIONS

1. Last date for receipt of tender is 03/06/25 upto 5.00 P.M. Which will be opened and negotiations will be held on 05/06/25 at 10.00 A.M. with the lowest quote only, if required.
2. This test will be done at mill site only.
3. Required transformer oil will be provided by the mill at site.
4. Required tool & Tackles will be arranged by the party for executing BDV test.
5. Party must have executed same work and certificate must be attached with tender.
6. 100% payment will be made after successfully load trial of transformer.
7. Rates should be FOR Mills, P&F, if applicable should be mentioned separately in percentage.
8. The envelope of tender should be subscribed as Tender for **Transformer BDV test**.
9. The undersigned reserves the right to reject/accept any or all tenders without assigning reasons.

A.E.(E)


General Manager


C.E.